HENEGHAN AND ASSOCIATES, P.C.



CIVIL ENGINEERS • LAND SURVEYORS WWW.HAENGR.COM

Since 1986

Addendum No. 2

for

Phase V System Improvements Contract "J"

for Jersey County Rural Water Company Jersey County, Illinois

H&A File No. 00139-4100 Contract "J" June 22, 2021

The Contract Documents prepared by Heneghan & Associates, P.C. for Phase V System Improvements Contract "J" for the Jersey County Rural Water Company, dated June 2021, are hereby amended or clarified as follows:

Changes/additions/clarifications to the project are as listed below:

Where called for on the plans or in the specifications restrained joint PVC may be substituted with the fusible PVC of the appropriate size and pressure class.

4-inch C900 DR 18 pipe may be substituted for 4-inch Class 250 SDR 17 PVC pipe on plan sheets 16, 17, and 18 only.

End of Addendum.

Seth W. Elliott, P.E., Project Manager Heneghan & Associates

the W. Elliott