HENEGHA

HENEGHAN AND ASSOCIATES, P.C.

CIVIL ENGINEERS · LAND SURVEYORS WWW.HAENGR.COM

Since 1986

Addendum No. 2

for

Phase V System Improvements Contract "L"

for Jersey County Rural Water Company Jersey County, Illinois

H&A File No. 00139-4100 Contract "L" June 22, 2021

The Contract Documents prepared by Heneghan & Associates, P.C. for Phase V System Improvements Contract "L" for the Jersey County Rural Water Company, dated June 2021, are hereby amended or clarified as follows:

PROJECT SPECIFICATIONS

Changes/additions/clarifications to the project specifications are as listed below:

Technical Provisions:

12.08 shall stub out 12-inch diameter ductile iron pipe a minimum of 5 feet beyond the drip edge of the tank.

75.05.D.6 Base Elbow to be 12-inch diameter.

75.06.D.5 Base Elbow to be 12-inch diameter.

End of Addendum.

Seth W. Elliott, P.E., Project Manager Heneghan & Associates

Sith W. Elliott