HENEGHAN AND ASSOCIATES, P.C.



CIVIL ENGINEERS • LAND SURVEYORS WWW.HAENGR.COM

Since 1986

ADDENDUM No. 3

Jefferson County Public Sewer District Weber Hill Terrace/Warren Woods Sanitary Sewer Improvements H&A File No. 80009-502

January 19, 2021

The Contract Documents prepared by Heneghan & Associates, P.C. for Weber Hill Terrace/Warren Woods Sanitary Sewer Improvements for the Jefferson County Public Sewer District, dated April 2020, are hereby amended or clarified as follows:

GENERAL

N/A

PROJECT DRAWINGS

Changes/additions/clarifications to the project drawings are as listed below:

- 1. Sheet 19 the following revisions clarify the intent of the grinder pump installation details:
 - a. The requirement for the visual alarm being visible from the road shall be removed.
 - b. The control panel shall be installed within approximately 8-10 feet of the grinder pump station. This work shall be coordinated with the onsite District Representative who will serve as a liaison between the contractor and the homeowners to ensure a suitable location.

PROJECT SPECIFICATIONS

Changes/additions/clarifications to the project specifications are as listed below:

- 1. For clarification, Section 32.22.C. Turfgrass Sod: does not apply to this contract directly as the work of this project consists of seeding for yard repair.
- 2. For clarification, Section 32.21.F.4 and 4.1 as previously amended in Addendum No.2: it shall be understood that roadway pavement replacement is to be oil and chip.
- 3. Section 52.03.D. shall be amended to remove SDR 9 and replaced with Pressure Pipe: SDR 11. SDR 11 shall be the only allowable polyethylene pipe material.

End of Addendum.

Seth W. Elliott, P.E.

Project Manager

Heneghan & Associates, P.C.